



# WEEKLY EROSION CONTROL INSPECTION

PROJECT:	Avalon Bay Stratford, CT	DATE:	August 15, 2013
CONTRACTOR:	AMEC	PROJECT NO.:	86 16038
PREPARED BY:	Ken Kohlbrenner, PE	REPORT NO.:	2
SIGNATURE:		PERMIT NO.:	IWWA #2001-9(M)

## 1. Initial Remarks/Comments:

Stump removal and initial grubbing is ongoing. Silt fence is installed around perimeter. Hay bale installation at silt fence is underway and ongoing.

## 2. Weather and Site Conditions:

<i>Time</i>	<i>Precipitation</i>	<i>Skies</i>	<i>Air Temp</i>	<i>Ground/Pavement Moisture</i>
3:30 pm	None	Clear	74°	Dry

## 3. Did observations reveal work *not* in compliance with the Erosion Control Plan?

Yes       No

If yes, explain and describe action taken.

Detail calls for hay bales installed behind silt fence (downstream in direction of flow). First section of hay bales installed upstream of silt fence. Notified Aaron Levy (Avalon) and Ken Terveen (AMEC) and was told it would be corrected and remainder of hay bales would be installed correctly.

## 4. Are the erosion and sediment control measures in place adequately installed to capture sediment in run-off from the site?

Yes       No

Comment:



# WEEKLY EROSION CONTROL INSPECTION

**5. Walk around the site perimeter to identify areas where sediment may escape from the site. Do areas to be disturbed drain to an area where sediment will be captured by silt fencing, hay bales, catch basins or equal measure?**

Yes       No

Comment: NA

**6. Are previously disturbed areas in need of hydro-seeding or manual seeding?**

Yes       No

Comment: NA

**7. Do disturbed areas drain to a drainage swale, sediment basin or protected stormwater systems?**

Yes       No

Comment: NA

Temporary stormwater management will be installed after tree clearing and grubbing is completed

**8. Are the construction vehicle entrances/exits free of sediment, mud or trash?**

Yes       No

Comment:

**9. Are erosion channels visible in the project area?**

Yes       No

Comment:



# WEEKLY EROSION CONTROL INSPECTION

## 10. Is dust control water spraying required?

Yes       No

Occurring as required?     Yes       No

Comment:

## 11. Are there disturbed areas that could cause ponding of run-off, other than a sediment basin?

Yes       No

Comment:

## 12. Are the silt fences installed as shown on the Erosion and Sediment Control Drawing?

Yes       No

Comment:

## 13. Additional Comments/Areas of Concern:

Discussed with Aaron Levy that his intent is to leave the existing asphalt access and parking area for as long as possible. Agreed that this would be acceptable, provided area is swept regularly and protected with hay bales during rain events. Construction anti-tracking pad may be required as work progresses into the site. Confirmed via email 8/15/13.

**Photographs to be Attached to Form as Needed**